

Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Luckiamute Valley Charter Schools- Bridgeport School

Date Collected	Time	Lab #	Sample Site	Lead Test Results, mg/liter	Action Level, mg/liter***
8/24/16	9:00	20160824-70	Computer Room	0.0129	0.020
8/24/16	9:01	20160824-71	5 th Grade Sink	0.0171	0.020
8/24/16	9:02	20160824-72	Girls Bathroom #1 main bldg.	0.0109	0.020
8/24/16	9:03	20160824-73	Girls bathroom sink #2 main bldg	0.0028	0.020
8/24/16	9:04	20160824-74	Boys bathroom sink #1 main bldg	0.0116	0.020
8/24/16	9:05	20160824-75	Boys Bathrooms sink #2 main bldg.	0.0114	0.020
8/24/16	9:06	20160824-76	Drinking F main bldg.	0.0014	0.020
8/24/16	9:07	20160824-77	Lunch room sink	ND @ 0.001	0.020
8/24/16	9:08	20160824-78	Main Bldg kitchen sink	0.0029	0.020
8/24/16	9:09	20160824-79	4 th Grade sink	0.0156	0.020
8/24/16	9:10	20160824-80	3 rd Grade sink	0.0056	0.020
8/24/16	9:11	20160824-81	3 rd Grade Drinking fountain	0.0057	0.020
8/24/16	9:12	20160824-82	Kinder bathroom sink	0.0040	0.020
8/24/16	9:13	20160824-83	Kinder DF	0.0105	0.020
8/24/16	9:14	20160824-84	Kinder classroom sink	0.0039	0.020
8/24/16	9:15	20160824-85	1 st grade bathroom sink	0.0262	0.020
8/24/16	9:16	20160824-86	2 nd grade bathroom sink	0.0234	0.020

RETESTED

10/20/16		20161020-096	1 st Grade bathroom sink	0.001	0.020
10/20/16		20161020-097	2 nd Grade Bathroom sink	0.001	0.020

Luckiamute Valley Charter Schools – Pedee Campus

6/29/16	n/a	20160629-072	Old basement sink	0.0047	0.020
6/29/16	n/a	20160629-071	Girls bathroom sink/8 th	0.0045	0.020
06/29/16	n/a	20160629-070	Boys bathroom sink/8 th	0.0048	0.020
06/29/16	n/a	20160629-073	New basement sink	0.0011	0.020
06/29/16	n/a	2016069-074	Kitchen sink-upstairs	0.0038	0.020
10/20/2016	n/a	20161020-098	7 th Grade Fountain	ND	0.020
10/20/2016	n/a	20161020-099	8 th Grade Fountain	0.0019	0.020

ND means No Detection at stated value.

*** Sample Size 250 mL Containers