

Lead Water Testing Results

Bridgeport Campus
17475 Bridgeport Rd.
Dallas, OR 97338

Fixture Location	Fixture ID#	Test Date	Initial Test Result	Retest Date	Test Results
Admin – Staff Room	SF-2018-01	06/14/19	ND @ 0.001		
Admin – Restroom right	BF -2018-02	06/14/19	0.0036		
Admin – Restroom left	BF-2018-03	06/14/19	0.0020		
Admin – Conference room	SF-2018-04	06/14/19	ND @ 0.001		
Main – Computer room	SF-1920-01	06/14/19	0.0018		
Main - Lunchroom	CF-1920-02	06/14/19	ND @ 0.001		
Main – Kitchen	KF-0920-03	06/14/19	ND @ 0.001		
Main – Hallway	WB-1920-04	06/14/19	0.0012		
Main – 5 th Grade	CF-1920-05	06/14/19	0.0032		
Main – Girls Restroom right	BF-1920-06	06/14/19	0.0036		
Main – Girls Restroom left	BF-1920-07	06/14/19	0.0038		
Main – Boys Restroom right	BF-1920-08	06/14/19	0.0031		
Main – Boys restroom left	BF-1920-09	06/14/19	0.0033		

* ND – No Detection @ Method Reporting Limit

* EPA Limit 0.015

Fixture Coding Key	
DW = Drinking Water Fountain	SF = Staff/Office Faucet
WB = Water Bottle Filler	KF = Kitchen/Food Prep
CF = Classroom Faucet	OS – Outside Spigot
BF = Bathroom Faucet	OT = Other (specify)