

Lead Water Testing Results

Pedee Campus
12975 Kings Valley Hwy
Monmouth, OR 97361

Fixture Location	Fixture ID#	Test Date	Initial Test Result	Retest Date	Test Results
Modular – Computer Lab	BF-2016-01	06/14/19	0.0010		
Modular – 6 th Grade Class	BF-2016-02	06/14/19	0.0010		
Main –Boys restroom-East-Window	BF-1925-03				
Main- Boys Restroom-East-Door	BF-1925-04				
Main- Girls restroom-East-Window	BF-1925-05				
Main-Girls Restroom-East-Door	BF-1925-06				
Main- Girls restroom-West	BF-1925-07				
Main-Boys restroom-West	BF-1925-08				
Main-Drinking Fountain-West	DW-1925-09				
Main –Drinking Fountain-East	DW-1925-10				
Main – Lunchroom East	CF-1925-11				
Main- Lunchroom West	CF-1925-12	06/14/19	0.0011		
Main – Kitchen-basement	KF-1925-13				
Main – Kitchen -Upper	KF-1925-14				

* ND – No Detection @ Method Reporting Limit

* EPA Limit 0.015

Fixture Coding Key	
DW = Drinking Water Fountain	SF = Staff/Office Faucet
WB = Water Bottle Filler	KF = Kitchen/Food Prep
CF = Classroom Faucet	OS – Outside Spigot
BF = Bathroom Faucet	OT = Other (specify)