

Bridgeport Campus

Building ID	Fixture Location	Fixture ID##	Sample ID	Test Date	Test Result	Retest Date
21900601	Staff Room	21900601-001SF	21900601-001SF25B	6/6/25	ND	Jun-29
21900601	Restroom right	21900601-002BF	21900601-002BF25B	6/6/25	ND	Jun-29
21900601	Restroom left	21900601-003BF	21900601-003BF25B	6/6/25	ND	Jun-29
21900601	Conference room	21900601-004SF	21900601-004SF25B	6/6/25	ND	Jun-29
21900600	KINDER	21900600-001SF	21900600-001SF25B	6/6/25	ND	Jun-29
21900600	Lunchroom	21900600-002CF	21900600-002CF25B	6/6/25	ND	Jun-29
21900600	Kitchen-prep sink	21900600-003KF	21900600-003KF25B	6/6/25	ND	Jun-29
21900600	Kinchen-Handwashing	21900600-004KF	21900600-004KF			Jun-29
21900600	Hallway	21900600-005WB	21900600-005WB25B	6/6/25	ND	Jun-29
21900600	5 th Grade	21900600-006CF	21900600-006CF25B	6/6/25	ND	Jun-29
21900600	Girls Restroom right	21900600-007BF	21900600-007BF25B	6/6/25	ND	Jun-29
21900600	Girls Restroom left	21900600-008BF	21900600-008BF25B	6/6/25	2.52 PPB	Jun-29
21900600	Boys Restroom right	21900600-009BF	21900600-009BF25B	6/6/25	2.52 PPB	Jun-29
21900600	Boys restroom left	21900600-010BF	21900600-010BF25B	6/6/25	2.26 PPB	Jun-29
21900605	Restroom-TITLE	21900605-001BF	21900605-001BF23A	6/9/23	ND	Jun-29
21900604	1 st Grade-Restroom	21900604-001BF	21900604-001BF23B	6/9/23	ND	Jun-29
21900604	2 nd Grade-Restroom	21900604-002BF	21900604-002BF23B	6/9/23	ND	Jun-29
21900602	3 rd Grade -Sink	21900602-001CF	21900602-001CF23B	6/9/23	ND	Jun-29
21900602	3 rd Grade – Drinking Fountain	21900602-002DW	21900602-002DW23B	6/9/23	0.00622	Jun-29

Fixture Coding Key

DW = Drinking Water Fountain	SF = Staff/Office Faucet
WB = Water Bottle Filler	KF = Kitchen/Food Prep
CF = Classroom Faucet	OS – Outside Spigot
BF = Bathroom Faucet	OT = Other (specify)